



Animal Facility SOP 38.2 Water Testing

Date Adopted	Adopted 11/19/20
Date Last Updated	11/18/2020
Prepared by	India Harper, Michelle Dennis, Ingrid Tulloch, Elizabeth Broussard
Reviewed by	Watson, 11/20

I. Purpose

This SOP will detail the policies and procedures related to water testing in the BSSC Vivarium.

II. Procedure

Water quality in the BSSC Vivarium is regulated by NEU-ION. Water quality reading should be observed weekly and the water quality reading noted in the log. If water quality level is **greater than 0.20 microsiemens/cm²**, notify the Facilities Manager and contact NEU-ION customer service at 1-800-678-4360. NEU-ION visits and checks the system quarterly and places their sticker in the log.

Customer ID: MORGU9.

The water quality meter is located near the wall on the machine next to the doors leading out of the Vivarium (the doors by the elevators). The photo below is of the water quality meter. Stickers with the last testing date are posted near the meter on the clipboard.



Appendix A

NEU-ION Maintenance Log Sheet :

https://docs.google.com/document/d/10NDAC4Blk9vyg8tEk0_yS2AK1PmODff9sgYjq2CXd9o/edit?usp=sharing